



**NOTES:**

1. WHEN REQUIRED BY THE UTILITY, GUARD POSTS SHALL BE INSTALLED FOR HYDRANTS OR OTHER CITY WATER FACILITIES ADJACENT TO STREETS WITHOUT CURBS, WITH ROLLED OR TYPE 'F' CURB, OR WITHIN 4 FEET OF PARKING LOT CURB OR CURB STOPS.
2. GUARD POSTS SHALL BE PAINTED IN ACCORDANCE WITH SECTION 2-14.
3. REFLECTIVE TAPE REQUIRED FOR COLORS OTHER THAN SAFETY YELLOW.
4. FOR ALL CASES, THE LOCATION OF GUARD POSTS SHALL MEET ADA REQUIREMENT THAT A MINIMUM 48-INCH CLEARANCE BE MAINTAINED FROM ANY OBSTRUCTION IN THE WALK.
5. GUARD POSTS SHALL BE LOCATED A MINIMUM OF 5 FEET FROM BCR, ECR OR DRIVEWAY APPROACH.
6. IN AREAS WITH ROLLED CURBS OR NO CURBS, THE DISTANCE FROM THE EDGE OF PAVEMENT TO THE GUARD POSTS SHALL BE AS DIRECTED BY THE UTILITY.

**WATER FACILITY GUARD POST**

**CITY OF MONTEREY PARK**

PUBLIC WORKS DEPARTMENT—WATER DIVISION

STANDARD NO.

**W-115**

DRAWN	BY XX	DATE XX/XX/XX	APPROVED WATER UTILITY MANAGER	DATE
REVISED	XX	XX/XX/XX		17/10/24
CHANGED	XX	XX/XX/XX	APPROVED CITY ENGINEER	DATE
				12/11/24

SHEET 1 OF 1