



**REQUIREMENTS:**

1. ONE (1) FOOT MINIMUM VERTICAL SEPARATION OUTSIDE DIAMETER (O.D.) TO O.D. FROM ALL OTHER UTILITIES AND/OR ENCASEMENT.
2. FIVE (5) FEET MINIMUM HORIZONTAL CLEARANCE O.D. TO O.D. FOR PARALLEL UTILITIES AND/OR ENCASEMENT.
3. FOR STORM DRAIN FACILITIES, FIVE (5) FEET HORIZONTAL SEPARATION REQUIRED.
4. BACKFILL 12-INCHES OF SAND (NOT LESS THAN 30) OVER THE TOP AND BOTTOM OF MPW WATER FACILITY. THE SAND BACKFILL SHALL BE BETWEEN THE CROSSING & SHALL BE COMPACTED TO 90% RELATIVE DENSITY BY WATER DENSIFICATION METHODS. NO FLOODING ALLOWED.
5. FOR SEWER FACILITIES SEE STD. NO. W-130. TEN (10) FEET HORIZONTAL FOR SEWER FACILITIES REQUIRED.
6. VERIFY OTHER UTILITY OWNERS SEPARATION REQUIREMENT. THE MOST STRINGENT SHALL APPLY.
7. WHERE MINIMUM SEPARATION/CLEARANCES CANNOT BE MET, UTILITY OWNER MUST SUBMIT A WRITTEN REQUEST TO MPK, WITH PROPOSED DESIGN FOR REVIEW AND APPROVAL BY MPK.
8. IF MPK EXISTING WATERLINE IS IN CONFLICT WITH PROPOSED UTILITY, THE PROPOSED UTILITY OWNER SHALL TAKE SOLE RESPONSIBILITY FOR COSTS INCURRED DUE TO ANY MODIFICATION, RELOCATION, OR ALTERATION OF MPK EXISTING FACILITIES CAUSED BY PROPOSED PROJECT TO THE SATISFACTION OF CITY OF MONTEREY PARK – WATER DIVISION.

**WATER MINIMUM SEPARATION FROM OTHER UTILITIES**

**CITY OF MONTEREY PARK**

PUBLIC WORKS DEPARTMENT – WATER DIVISION

STANDARD NO.

**W-131**

	BY	DATE
DRAWN	AM	10/02/24
REVISED	DZ	10/02/24
CHANGED	XX	XX/XX/XX

APPROVED  
WATER UTILITY MANAGER

*[Signature]*

DATE 12/10/24

APPROVED  
CITY ENGINEER

*[Signature]*

DATE 12/11/24

SHEET 1 OF 1