



LEGEND	
A	TAPPING TEE OR FLG TEE
B	WATER MAIN
C	4" GATE VALVE FLG X MJ
D	THRUST BLOCK PER STD DWG NO 106
E	4" MIN DIP
F	TYPICAL BLOW-OFF STD DWG NO 102 SHT 3
G	MJ X MJ 90° BEND
H	SADDLE W/ TAP SIZE PER PLANS
I	CAP MJ W/ 2" PLUG
J	MJ MEGA LUG STYLE OR APPROVED EQUAL

NOTES:

1. 2" SERVICE MIN (4) TO MAX (6) PER MANIFOLD OR 1" SERVICE MIN (4) TO MAX (10) PER MANIFOLD
2. BLOWOFF OR IRRIGATION METER AT END OF MANIFOLD
3. SERVICE TAPS WILL BE SPACED TO ALLOW METER BOXES TO BE CENTERED ON METER AND MIN. 2" SEPARATION BETWEEN BOXES

TYPICAL MANIFOLD ASSEMBLY FOR 4 TO 10 1-INCH SERVICES

CITY OF MONTEREY PARK
PUBLIC WORKS DEPARTMENT - WATER DIVISION

STANDARD NO.
W-205

DRAWN	BY	DATE
	AM	10/02/24
REVISED	DZ	10/02/24
CHANGED	XX	XX/XX/XX

APPROVED WATER UTILITY MANAGER	DATE	12/10/24
APPROVED CITY ENGINEER	DATE	12/11/24

SHEET 1 OF 1