

NOTES:

1. MATERIALS AND INSTALLATION SHALL CONFORM WITH THE APPLICABLE SECTIONS OF MONTEREY PARK WATER DEPARTMENT SPECIFICATIONS FOR DOMESTIC WATER SYSTEMS.
2. FINISH COLOR SHALL BE DESERT TAN, INSIDE AND OUT.

WATER SAMPLING STATION

CITY OF MONTEREY PARK
PUBLIC WORKS DEPARTMENT - WATER DIVISION

STANDARD NO.

W-607

DRAWN	BY AM	DATE 10/02/24
REVISED	DZ	10/02/24
CHANGED	XX	10/02/24

APPROVED
WATER UTILITY MANAGER

[Signature]

DATE 12/10/24

APPROVED
CITY ENGINEER

[Signature]

DATE 12/11/24

SHEET 1 OF 2

LEGEND			
A	DOUBLE STRAP BRONZE SADDLE	Δ L	PUMP CONNECTOR
B	1" BRASS BALL CORPORATION STOP FORD FB1000-4	Δ M	BRASS NOZZLE WITH THREADS
C	1" SWT X F.I.P. COUPLING ATTACHED TO STRAIGHT COUPLING	Δ N	IRON HANDLE
D	1" COPPER TUBING*WRAP WITH 10 MIL WRAP TAPE	Δ O	SAMPLING STATION WITH HINGED COVER ARMOR CAST #P6002010 OR APPROVED EQUAL
Δ E	ANGLE METER STOP - 1" FORD #KV43-444W OR 2" FORD #FV43-777W	Δ P	PADLOCK PROVISION
Δ F	3/8" BRASS PIPE INSIDE 1" BRAS PIPE	Q	2'-6" X 4'-6" X 4" THICK CONCRETE PAD
Δ G	BRASS VALVE BODY & ASSEMBLY	R	1" METER PROVIDED BY THE CITY
Δ H	1/4" BRASS ELBOW	S	FIBERGLASS ARMORCAST PRODUCT METER BOX & COVER
Δ I	1/4" COPPER TUBING	T	1" SWT X F.I.P. COUPLING ATTACHED TO STRAIGHT COUPLING
Δ J	ALUMINUM BASE	U	STAIGHT METER COUPLING FORD #C38-44-2.625
K	BRASS PET COCK	V	ARMORCAST PRODUCTS #66 METER VAULT OR CITY APPROVED EQUAL

Δ - TO BE SUPPLIED BY THE CITY



WATER SAMPLING STATION

CITY OF MONTEREY PARK

PUBLIC WORKS DEPARTMENT - WATER DIVISION

STANDARD NO.

W-607

DRAWN	BY AM	DATE 10/02/24	APPROVED WATER UTILITY MANAGER		DATE 12/10/24
REVISED	DZ	10/02/24	APPROVED CITY ENGINEER		DATE 12/11/24
CHANGED	XX	10/02/24			

SHEET 2 OF 2