



NOTES:

1. INSTALL INSULATING BLANKET BETWEEN METALLIC PIPELINES WHEN THE DISTANCE SEPARATING THE PIPE LINES IS 12" OR LESS.
2. MAKE SURE BLANKET IS FLAT ON SOIL BACKFILL AND CENTERED BETWEEN THE PIPES.
3. BLANKET SHALL BE SQUARE AND MIN. 12" LARGER THAN THE DIAMETER OF THE LARGEST PIPELINE INVOLVED.
4. APPROVED MANUFACTURER: NEOPRENE BLENDED SHEET, STYLE NO.10 SMOOTH FINISH BY BILTRITE, OR APPROVED EQUAL.

INSULATING BLANKET

CITY OF MONTEREY PARK
PUBLIC WORKS DEPARTMENT - WATER DIVISION

STANDARD NO.

W-610

DRAWN	BY AM	DATE 10/02/24	APPROVED WATER UTILITY MANAGER	<i>[Signature]</i>	DATE	12/10/24
REVISID	DZ	10/02/24	APPROVED CITY ENGINEER	<i>[Signature]</i>	DATE	12/11/24
CHANGED	XX	XX/XX/XX				

SHEET 1 OF 1