



REFERENCES:

1. STATE OF CALIFORNIA, DEPT. OF WATER RESOURCES BULLETIN 74. "WATER WELL STANDARDS"
2. CITY OF MONTEREY PARK MUNICIPAL CODE

NOTES:

1. ALL WORK SHALL BE DONE UNDER PERMIT ISSUED BY THE UTILITIES DIRECTOR AND SUBJECT TO HIS INSPECTION.
2. CASTING TO BE PERFORATED, IF NECESSARY, TO INSURE BACKFILLING OF ANNULAR SPACE OUTSIDE OF CASING.
3. BACKFILL MATERIAL TO BE INTRODUCED UNDER PRESSURE TO CLOSE ALL VOIDS IN GRAVEL PACKED WELLS.
4. ACCEPTABLE BACKFILL MATERIAL TO BE:
 - A. NEAT CEMENT: 5-7 GAL PER SACK
 - B. CEMENT GROUT: 5-57 GAL PER SACK, 2 PARTS SAND/1 PART CEMENT
 - C. CONCRETE: CLASS B, 5 SACK/CU. YARD
 - D. BENTONITE (UP TO 5 PERCENT BY WIEGHT OF CEMENT) OR SIMILAR WORKABILITY AGENTS MAY BE USED.

DESTRUCTION OF ABANDONED WATER WELLS

CITY OF MONTEREY PARK

PUBLIC WORKS DEPARTMENT - WATER DIVISION

STANDARD NO.

W-630

	BY	DATE
DRAWN	AM	10/02/24
REVISED	DZ	10/02/24
CHANGED	XX	XX/XX/XX

APPROVED
WATER UTILITY MANAGER

DATE

[Signature]
12/10/24

APPROVED
CITY ENGINEER

DATE

[Signature]
12/11/24

SHEET 1 OF 1